

BICSI

Exam Questions DCDC-003.1

BICSI Data Center Design Consultant (DCDC)



NEW QUESTION 1

What is the recommended fire suppression system for a data center?

- A. Water-based
- B. Gas-based
- C. Foam-based
- D. Powder-based
- E. None of the above

Answer: B

NEW QUESTION 2

What is the low temperature that must be maintained in a data center according to NEB standards?

- A. 55 degrees
- B. 60 degrees
- C. 65 degrees
- D. 70 degrees
- E. 75 degrees

Answer: C

NEW QUESTION 3

What is minimum recommended generator fuel storage amount?

- A. enough to run 4 to 16 hours at full load
- B. enough to run 24 to 36 hours at full load
- C. enough to run 48-72 hours at full load
- D. enough to run up-to a week at full load

Answer: C

NEW QUESTION 4

What is the minimum distance recommended between a data center's backup generator and the main data center building?

- A. 10 feet
- B. 20 feet
- C. 30 feet
- D. 40 feet

Answer: C

NEW QUESTION 5

what is the ANSI/TIA-942 recommended operational temperature

- A. 60F to 75F
- B. 68F to 77F
- C. 80F to 90F
- D. -10??C to +45??C

Answer: B

NEW QUESTION 6

What are the 3 types of Authentication for access control?

- A. Type 4 - What you possess
- B. Type 5 - What you desire
- C. Type 6 - What you create
- D. Type 1 - What you have Type 2 - What you know Type 3 - What you are

Answer: D

NEW QUESTION 7

What is the ASHRAE TC 9.9 recommended range for humidity levels in a data center?

- A. 20-50%
- B. 40-60%
- C. 60-80%
- D. 80-100%

Answer: B

NEW QUESTION 8

what are the two rooms that may require 2 exits?

- A. the electrical Room and battery room
- B. Equipment Room and Security Rooms
- C. Mechanical Room and Electrical
- D. Computing rooms And Storage rooms
- E. Water Supply Rooms

Answer: A

NEW QUESTION 9

What kind of height clearance should data center access roads have?

- A. A Minimum clear road width and sixteen (16) ft height clearance throughout.
- B. A Minimum clear road width and six(06) ft height clearance throughout.
- C. A Minimum clear road width with fourteen (14)ft hight clearance throughout.
- D. None Of The Above.

Answer: C

NEW QUESTION 10

What is the recommended floor loading capacity for a data center?

- A. 1000 lbs per s
- B. ft.
- C. 1250 lbs per s
- D. ft.
- E. 1500 lbs per s
- F. ft.
- G. 1750 lbs per s
- H. ft.
- I. 2000 lbs per s
- J. ft.

Answer: C

NEW QUESTION 10

What is recommended size ratio of Secure Storage Area?

- A. 5% of Computer Room Space
- B. 10% or greater than Available Floor Space
- C. 15-20% more than Computer Room's Cross Sectional Area
- D. 10% of Computer Room's Net Square Footage
- E. None Of These

Answer: D

NEW QUESTION 13

What is the minimum height of a ceiling in a data center or telecommunications room?

- A. Five feet from finished floor to any obstruction, sprinklers, lighting
- B. eight feet from finished floor to any obstruction, sprinklers, lighting
- C. ten feet from finished foroor to asany oos obstruction, sprinklers, lighting(correct)
- D. twelve feet from finished floot to pay constructionjssgspritesari sek

Answer: C

NEW QUESTION 18

According to NEB, what is the recommended rate of temperature change per hour in a data center?

- A. 36 degrees
- B. 45 degrees
- C. 54 degrees
- D. 63 degrees
- E. 72 degrees

Answer: C

NEW QUESTION 19

What is the clearance required between the cold aisle and the CRAC unit?

- A. 2 feet
- B. 4 feet
- C. 6 feet
- D. 8 feet

Answer: D

NEW QUESTION 22

what additional fuel filtering is required for generators in class F3 and F4 facilities

- A. two-stage, spin-on-type fuel filters
- B. four stage, paper-type fuel filters
- C. five stage, mesh type fuel filters
- D. three stage, spin-on-type fuel filters

Answer: D

NEW QUESTION 26

what is typical entrance room power requirement?

- A. 500, to 1500 watts per access provider
- B. More than 2000 KW
- C. exactly or less than 300KW
- D. More than about Million watts

Answer: A

NEW QUESTION 28

What are the factors that affect availability?

- A. Operational Requirements
- B. Operational Availability
- C. Impact of Downtime
- D. All of the above

Answer: D

NEW QUESTION 30

What is the minimum required headroom for overhead cable tray?

- A. 3"
- B. 6"
- C. 9"
- D. 12"

Answer: B

NEW QUESTION 35

What is the minimum slab floor to ceiling height recommended?

- A. 12feetminimum
- B. 14feetminimum
- C. 15feetminimmum
- D. 16feetminimum

Answer: C

NEW QUESTION 38

what is another main function of the entrance room?

- A. to house the telecommunications main grounding busbar
- B. to store backup telecommunication devices
- C. as a dedicated location outside building
- D. None of these

Answer: A

NEW QUESTION 39

what is the recommended height, of the support room pathway

- A. 9 ft
- B. 8ft
- C. 7ft
- D. 6ft

Answer: A

NEW QUESTION 42

What 3 standards books should be followed for data center grounding and bonding?

- A. TIA 942, TIA 607 and IEEE 1100

- B. UL 467, UL 96A and NFPA 70
- C. TIA 568, ANSI/TIA-606-B and TIA 568-C.1
- D. ASHRAE Standard 90.1, ASHRAE Standard 62.1 and ASHRAE Standard 55

Answer: A

NEW QUESTION 44

What is the difference between a single bus and a dual bus power distribution system?

- A. Single bus has only one power source while dual bus has two independent power sources
- B. Single bus is more reliable than dual bus
- C. Dual bus is more cost-effective than single bus
- D. Single bus is more flexible and adaptable to changing needs than dual bus

Answer: A

NEW QUESTION 48

What is typically considered the demarcation point for electrical utility at a data center?

- A. The transformer
- B. The UPS
- C. The generator
- D. The switchboard

Answer: A

NEW QUESTION 49

Where should power cable be ran in an access floor?

- A. Hot aisle
- B. Cold aisle
- C. Above the access floor
- D. Below the access floor

Answer: B

NEW QUESTION 51

What is the appropriate fire rating requirements for a command center?

- A. 1/2 hour
- B. 1 hour
- C. 2 hours
- D. 3 hours

Answer: B

NEW QUESTION 52

What are the speed and distance limitations of ESCON?

- A. 1 Gbps @ up to 100m
- B. 10 Gbps @ up to 40km
- C. 17 MB/s @ up to 60km
- D. 100 Mbps @ up to 20km

Answer: C

NEW QUESTION 53

What is the recommended amount of fuel supply to be available to a class F4 data center?

- A. 24 hours
- B. 48 hours
- C. 72 hours
- D. 96 hours

Answer: D

NEW QUESTION 56

what is minimum recommended space for secured storage area?

- A. 100 square feet B 240 square feet
- B. 250 square feet
- C. 280 square feet
- D. None of above

Answer: C

NEW QUESTION 59

What is the high temperature that must be maintained in a data center according to TIA- 942?

- A. 70 degrees
- B. 75 degrees
- C. 77 degrees
- D. 80 degrees
- E. 85 degrees

Answer: C

NEW QUESTION 62

What are three primary considerations in designing the power systems space plan?

- A. Energy utilization, efficiency of cooling and redundant generators
- B. Physical security, environmental monitoring, backup power source
- C. Reduce transmission loss, conduit path minimizing & spacing requirement for system
- D. Leakage current control, firewall protection & hardening redundancy

Answer: C

NEW QUESTION 66

What is the United States Average Power Utility Outage Annually And What Is The Average Repair Time?

- A. 2.5 outages annually, with average repair time of approximately 7 hours
- B. 1 outage annually, with average repair time of approximately eight hours
- C. 1.86 outages annually, with average repair time of four hours
- D. Three outages annually, with an unknown average repair time

Answer: C

NEW QUESTION 71

What Enhanced Fujita Scale level is commonly used in wind loading calculations?

- A. EF1,73-112 mph
- B. EF2,113-157mph
- C. EF3,158-206mph
- D. EF4,207-260 mph

Answer: D

NEW QUESTION 75

What is the acceptable dew point level in a data center according to TIA-942?

- A. 60 degrees
- B. 65 degrees
- C. 69.8 degrees
- D. 75 degrees
- E. 80 degrees

Answer: C

NEW QUESTION 78

What is the acceptable rate of temperature change per hour in a data center according to TIA-942?

- A. 5 degrees
- B. 7 degrees
- C. 9 degrees
- D. 12 degrees
- E. 15 degrees

Answer: C

NEW QUESTION 81

What is the preferred location of the power distribution unit?

- A. a service gallery outside the computer room, if the A H J and feeder distances allow
- B. under each server rack
- C. in an unused area of another floor
- D. inside a ventilation duct

Answer: A

NEW QUESTION 83

where should the vendor storage area be located?

- A. far away from loading dock
- B. inside data center
- C. offsite
- D. adjacent or near secured loading dock

Answer: D

NEW QUESTION 84

How often is there typically a technology refresh in a data center?

- A. Every 1-2 years
- B. Every 3-5 years
- C. Every 7-10 years
- D. There is no typical refresh cycle

Answer: B

NEW QUESTION 87

where should printers be located

- A. beside high traffic areas
- B. near equipment that has active air flow to cool them down
- C. in a dedicated print room with dedicated air handling system
- D. placed outdoor, away from building facilities

Answer: C

NEW QUESTION 91

A. To Supply Primary Power To Data Center Equipment

- A. To backup data center equipment
- B. To supply electricity only during regular working hour
- C. To reduce carbon footprint in the utility industry

Answer: B

NEW QUESTION 92

What is a possible downside to customer-owned maintenance holes?

- A. fire risk near data center property
- B. susceptibility to theft or damage by unauthorized personnel
- C. poor aesthetic appearance around facility exterior
- D. leaks leading to water infiltration into data center

Answer: D

NEW QUESTION 93

when is a battery room required to have electrolyte spill containment and exhaust systems?

- A. when using Lithium batteries
- B. when using Nickel Cadmium batteries
- C. when using Sealed lead-acid-batteries
- D. when the batteries contain liquid, free-flowing electrolyte
- E. All of Above

Answer: D

NEW QUESTION 96

What is the recommendation regarding row length?

- A. Do not exceed 20 racks in length and dead-end rows not to exceed ten racks long
- B. Maximum twenty-five racks in each row only
- C. Ten Racks in Length
- D. None
- E. All

Answer: A

NEW QUESTION 100

What is the clearance required between cabinets and the perimeter wall?

- A. 2 ft
- B. 4 ft

- C. 6 ft
- D. 8 ft

Answer: B

NEW QUESTION 105

What is the smoke development rating required for all materials hosted in a containment system?

- A. 150
- B. 300
- C. 450
- D. 600

Answer: C

NEW QUESTION 110

What is the third preference regarding electricity supply?

- A. At Least Two Circuits From Same Power Grid But Different Substations And Separate Paths
- B. One Balanced Feeder Coordinated With Upstream Backup Feed
- C. One Circuit From Single Sub Station Fed Via Additional Path from Alternate Power Grid
- D. Two Balanced Feeds With Same Voltage Derived From A Single Distribution Station

Answer: A

NEW QUESTION 112

What is the minimum separation distance of underground telecommunications and utility cabling in same route?

- A. 2 feet minimum along entire route
- B. 6 feet minimum along entire route
- C. no need for separation as long as they are enclosed in different conduit systems.
- D. none of the above

Answer: B

NEW QUESTION 116

why does the entrance room designer need to meet with each anticipated access provider?

- A. To determine their electrical, space, interface, and other facility requirements
- B. As an alternative approach to save cost
- C. To know about hardware requirement only
- D. none of above

Answer: A

NEW QUESTION 118

Where is the recommended location for remote power panels?

- A. at one or both ends of an equipment row
- B. outside the building
- C. inside a sealed room
- D. suspended from ceiling

Answer: A

NEW QUESTION 121

What is the switch gear in an electrical distribution design responsible for?

- A. Transforming voltage
- B. Delivering power directly to the server racks
- C. Transferring control between utility and generator
- D. Managing cooling systems

Answer: C

NEW QUESTION 122

FILL IN THE BLANK

what is the hydrogen maximum for a data center?

- A. 1 % of total room volume
- B. 15%of total room volume
- C. 20%of total room volume
- D. None Of These answers

Answer: A

NEW QUESTION 127

What is the recommended raised floor height, especially for high density needs and underfloor HVAC?

- A. 24"
- B. 30"
- C. 36"
- D. 42"

Answer: C

NEW QUESTION 132

Apart from marine cargo ports, hazardous material transport roadways, transportation roadways, and flight paths, what other things should a data centre be at least one mile away from?

- A. Waste-disposal units and dumpsites only.
- B. Petroleum storage installations like petrol stations & oil storage facilities only.
- C. Fireworks manufacturing companies only.
- D. All of The Above

Answer: D

NEW QUESTION 136

What types of electrical equipment is typically located inside the computer room

- A. power distribution units, not power distribution equipment, remote power panels, and power strips
- B. transformers only
- C. Uninterrupted Power Supply (UPS) only
- D. Circuit Breakers only

Answer: A

NEW QUESTION 137

What is the minimum size conductor from the TMGB to the building main ground bus?

- A. 80mm (150MCM) bare copper
- B. 100mm (200MCM) bare copper
- C. 130mm (250MCM) bare copper
- D. 160mm (300MCM) bare copper
- E. 200mm (400MCM) bare copper

Answer: C

NEW QUESTION 141

What is the Typical Voltage Of A Utility Sub-Station?

- A. Low voltage at 480 or less volts
- B. Medium to Low-voltage range between 270 to13800 volts
- C. High voltage at a stunningly high rate
- D. The United States uses only Direct Currents DC

Answer: B

NEW QUESTION 143

What are the recommended computer room delivery pathway dimensions

- A. 10 feet long by 4 feet deep by 8 feet high
- B. 20 feet long by 6 feet deep by 10 feet high
- C. 15 feet long by 5 feet deep by7feet high
- D. 14 feet long and has a depth dependent on rack layout.

Answer: A

NEW QUESTION 145

what is the ASHRAE recommended operational temperature.

- A. Minimum =54 degrees[F]/12 degrees[C] Maximum=88 degrees [F]/31degrees[C]
- B. Minimum =64 degrees[F]/18 degrees[C] Maximum=80 .6degrees [26 .9]<30 del="> [C]
- C. Minimum <=50 degree[A] Maximum =>200Degrees[B]
- D. Maximum <=33 Degree[XEIYCPJZDKLTWGBNMFUAHSRQV][/33][64]="> Minimum >=18Degree[KOVBYXPZXWMFGUTANLHQRSRDCJE]</18>

Answer: B

NEW QUESTION 149

What is the highest allowable elevation for a data center site?

- A. 2,500 ft
- B. 5,000 ft
- C. 7,500 ft
- D. 10,000 ft
- E. 12,500 ft

Answer: D

NEW QUESTION 154

What room should have its own dedicated air handling system apart from the computer room?

- A. Electrical Room
- B. Break Room
- C. Printer Room
- D. Storage Room
- E. Telecommunications Room

Answer: C

NEW QUESTION 156

When is a battery room required to have electrolyte spill containment and exhaust systems?

- A. when the battery weight exceeds 500 pounds
- B. When the ceiling suspended load capacity is below 20 pounds per square foot
- C. when the potential for outgassing hydrogen exists
- D. When corrosive fumes are detected in operation room

Answer: C

NEW QUESTION 161

What is the recommended height of a ceiling in a data center or telecommunications room?

- A. 012 ft
- B. 1015ft(correct)
- C. 1112ft
- D. 1120151

Answer: B

NEW QUESTION 162

what are the dead loads of a structure?

- A. Static loads due to force of gravity on fixed building elements (correct)
- B. Dynamic loads due to external forces like suction winds and rain
- C. Loads due to snow, wash
- D. Temperature fluctuations leading to expansion and contraction

Answer: A

NEW QUESTION 164

.....

Thank You for Trying Our Product

We offer two products:

1st - We have Practice Tests Software with Actual Exam Questions

2nd - Questions and Answers in PDF Format

DCDC-003.1 Practice Exam Features:

- * DCDC-003.1 Questions and Answers Updated Frequently
- * DCDC-003.1 Practice Questions Verified by Expert Senior Certified Staff
- * DCDC-003.1 Most Realistic Questions that Guarantee you a Pass on Your FirstTry
- * DCDC-003.1 Practice Test Questions in Multiple Choice Formats and Updatesfor 1 Year

100% Actual & Verified — Instant Download, Please Click
[Order The DCDC-003.1 Practice Test Here](#)