

Exam Questions NSE7_OTS-6.4

Fortinet NSE 7 - OT Security 6.4

https://www.2passeasy.com/dumps/NSE7_OTS-6.4/



NEW QUESTION 1

An OT network architect needs to secure control area zones with a single network access policy to provision devices to any number of different networks. On which device can this be accomplished?

- A. FortiGate
- B. FortiEDR
- C. FortiSwitch
- D. FortiNAC

Answer: D

NEW QUESTION 2

What two advantages does FortiNAC provide in the OT network? (Choose two.)

- A. It can be used for IoT device detection.
- B. It can be used for industrial intrusion detection and prevention.
- C. It can be used for network micro-segmentation.
- D. It can be used for device profiling.

Answer: CD

NEW QUESTION 3

Which three common breach points can be found in a typical OT environment? (Choose three.)

- A. Global hat
- B. Hard hat
- C. VLAN exploits
- D. Black hat
- E. RTU exploits

Answer: CDE

NEW QUESTION 4

Refer to the exhibit and analyze the output.

Which statement about the output is true?

- A. This is a sample of a FortiAnalyzer system interface event log.
- B. This is a sample of an SNMP temperature control event log.
- C. This is a sample of a PAM event type.
- D. This is a sample of FortiGate interface statistics.

Answer: A

NEW QUESTION 5

Which three Fortinet products can be used for device identification in an OT industrial control system (ICS)? (Choose three.)

- A. FortiNAC
- B. FortiManager
- C. FortiAnalyzer
- D. FortiSIEM
- E. FortiGate

Answer: ACD

NEW QUESTION 6

Refer to the exhibit.

You need to configure VPN user access for supervisors at the branch and HQ sites using the same soft FortiToken. Each site has a FortiGate VPN gateway. What must you do to achieve this objective?

- A. You must use a FortiAuthenticator.
- B. You must register the same FortiToken on more than one FortiGate.
- C. You must use the user self-registration server.
- D. You must use a third-party RADIUS OTP server.

Answer: A

NEW QUESTION 7

An OT network administrator is trying to implement active authentication. Which two methods should the administrator use to achieve this? (Choose two.)

- A. Two-factor authentication on FortiAuthenticator
- B. Role-based authentication on FortiNAC

- C. FSSO authentication on FortiGate
- D. Local authentication on FortiGate

Answer: AB

NEW QUESTION 8

Refer to the exhibit

In the topology shown in the exhibit, both PLCs can communicate directly with each other, without going through the firewall.

Which statement about the topology is true?

- A. PLCs use IEEE802.1Q protocol to communicate each other.
- B. An administrator can create firewall policies in the switch to secure between PLCs.
- C. This integration solution expands VLAN capabilities from Layer 2 to Layer 3.
- D. There is no micro-segmentation in this topology.

Answer: D

NEW QUESTION 9

Refer to the exhibit, which shows a non-protected OT environment.

An administrator needs to implement proper protection on the OT network.

Which three steps should an administrator take to protect the OT network? (Choose three.)

- A. Deploy an edge FortiGate between the internet and an OT network as a one-arm sniffer.
- B. Deploy a FortiGate device within each ICS network.
- C. Configure firewall policies with web filter to protect the different ICS networks.
- D. Configure firewall policies with industrial protocol sensors
- E. Use segmentation

Answer: ACD

NEW QUESTION 10

An OT network architect must deploy a solution to protect fuel pumps in an industrial remote network. All the fuel pumps must be closely monitored from the corporate network for any temperature fluctuations.

How can the OT network architect achieve this goal?

- A. Configure a fuel server on the remote network, and deploy a FortiSIEM with a single pattern temperature security rule on the corporate network.
- B. Configure a fuel server on the corporate network, and deploy a FortiSIEM with a single pattern temperature performance rule on the remote network.
- C. Configure a fuel server on the remote network, and deploy a FortiSIEM with a single pattern temperature performance rule on the corporate network.
- D. Configure both fuel server and FortiSIEM with a single-pattern temperature performance rule on the corporate network.

Answer: B

NEW QUESTION 10

Refer to the exhibit.

Which statement about the interfaces shown in the exhibit is true?

- A. port2, port2-vlan10, and port2-vlan1 are part of the software switch interface.
- B. The VLAN ID of port1-vlan1 can be changed to the VLAN ID 10.
- C. port1-vlan10 and port2-vlan10 are part of the same broadcast domain
- D. port1, port1-vlan10, and port1-vlan1 are in different broadcast domains

Answer: D

NEW QUESTION 12

When device profiling rules are enabled, which devices connected on the network are evaluated by the device profiling rules?

- A. Known trusted devices, each time they change location
- B. All connected devices, each time they connect
- C. Rogue devices, only when they connect for the first time
- D. Rogue devices, each time they connect

Answer: C

NEW QUESTION 13

What can be assigned using network access control policies?

- A. Layer 3 polling intervals
- B. FortiNAC device polling methods
- C. Logical networks
- D. Profiling rules

Answer: D

NEW QUESTION 15

.....

THANKS FOR TRYING THE DEMO OF OUR PRODUCT

Visit Our Site to Purchase the Full Set of Actual NSE7_OTS-6.4 Exam Questions With Answers.

We Also Provide Practice Exam Software That Simulates Real Exam Environment And Has Many Self-Assessment Features. Order the NSE7_OTS-6.4 Product From:

https://www.2passeasy.com/dumps/NSE7_OTS-6.4/

Money Back Guarantee

NSE7_OTS-6.4 Practice Exam Features:

- * NSE7_OTS-6.4 Questions and Answers Updated Frequently
- * NSE7_OTS-6.4 Practice Questions Verified by Expert Senior Certified Staff
- * NSE7_OTS-6.4 Most Realistic Questions that Guarantee you a Pass on Your FirstTry
- * NSE7_OTS-6.4 Practice Test Questions in Multiple Choice Formats and Updatesfor 1 Year